

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1256

Dated: 27/6/2025

It is certified that an inspection team headed by Lab Staff (Ashish and Prince)

(Name of Officers with designation) from District Water Testing Lab PHED

inspected the G.D. GOENKA PUBLIC SCHOOL, BHIWANI, ROHTAK ROAD, BHIWANI

(Name & Address of the school) on 06/06/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1255 and 1213 dated 27/6 & 14/6/2025

of District Water Testing Laboratory (PHED Lab) certified that the

G.D. GOENKA PUBLIC SCHOOL, BHIWANI (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 MONTHS...

Signature with Seal:

Name: Rajesh Kumar

Designation: Chemist

Name & Address of the Office / Department:

To
G.D. GOENKA PUBLIC
SCHOOL, BHIWANI

(Name & Address of the Institution)

DWTL, Vidya Nagar,
Meham Road, Bhiwani

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Ashish
Principal
GD GOENKA PUBLIC SCHOOL
BHIWANI

Singh
Director
GD Goenka Public School
Bhiwani

Memo No:- 1255

Date:- 27/06/2025

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : BHW/01763/6/2025 / Private	Sample Details	Date & Time
Sender : G D GOENKA PUBLIC SCHOOL	Collected By	SUMIT KUMAR
Location : , 5 KM STONE, ROHTAK-BHIWANI ROAD, BHIWANI	Collection Date	20/06/2025 at 12:42
Sample Description : Drinking Water	Received at lab	20/06/2025 at 16:02
Latitude / Longitude : 76.202804 / 28.798706	Analysis Start Date	23/06/2025
	Analysis End Date	23/06/2025
	Sample Quantity	2 ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.17	1 NTU	5 NTU	APHA 24th Edition -2130 B
	Taste	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2160C
3	Odour	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2150B
4	Color	1	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120B
5	Total Dissolved Solids @ 180°C ± 2°C	63.7	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO ₃	40	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	6.02	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	6.08	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	15	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	17.73	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as SO ₄	12	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
12	Fluoride as F	0.1	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
13	Iron as Fe	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate as NO ₃	0.18	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
	pH @ 25°C	7.89	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED BHIWANI Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by : Prince

RAJEEV KUMAR ,CHEMIST
DISTRICT WATER TESTING LABORATORY BHIWANI
email:-chemist.bhiwani@phedharyana.gov.in

Adarshani
Principal
GD GOENKA PUBLIC SCHOOL
BHIWANI

Director *Satish*
GD Goenka Public School
Bhiwani

Memo No:- 1213

Date:- 14/06/2025

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	BHW/01508/6/2025	Sample Details	Date & Time
Sample Classification:	Private	Collected By	SUMIT KUMAR,9416524684
Sender:	G D GOENKA PUBLIC SCHOOL	Collection Date	04/06/2025 at 16:28
Location :-	, 5 KM. STONE, ROHTAK-BHIWANI ROAD,BHIWANI	Received at lab	06/06/2025 at 15:01
Latitude :- 76.203071	Longitude :- 28.799480	Tested at Lab	14/06/2025

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	00	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in BHIWANI lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"



RAJEEV KUMAR,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY BHIWANI
email:-chemist.bhiwani@phedharyana.gov.in

-----End of Report-----.


Principal
GD GOENKA PUBLIC SCHOOL
BHIWANI

Director 
GD Goenka Public School
Bhiwani